

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLEARNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

September 17, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

**Via Email to: wes@weavercm.com**  
**No Hard Copy to Follow**

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	07501-005
Date of Submittal:	August 7, 2012
Title:	Blower Building Metal Roof Panels
Specification Section:	07501 – Metal Roof and Wall Panels
Manufacturers:	Heath Steel; Metal Sales Manufacturing Company

The referenced submittal has been stamped "**Make Corrections Noted**" and "**Submit Specified Item**". Our comments are as follows:

1. The shop submittal subject line indicates this as:

"Submittal for the Blower Building Metal Wall Panels." This should be changed on shop submittal logs to be Blower Building Metal "Roof" Panels. **Make Corrections Noted**

2. The shop submittal SPEC SECTION line indicates this as:

07501 – Metal "Wall" Panels. This should be changed to be 07501 – Metal "Roof and Wall" Panels. **Make Corrections Noted**

3. Sheet RS1 of 1

a. A note on the drawings requests the Engineer of Record "...review the roof clip fastener pull-out value and specify the required roof clip row spacing..." The Construction Drawings indicate 5/8-inch plywood sheathing will be used. The contractor, installer, supplier and manufacturer must guarantee to the Owner that materials and installation are all in accordance with the project specifications. **Submit Specified Item**

Mr. Wes Weaver  
September 17, 2012  
Page 2

4. Because the manufacturer, supplier, installer and Contractor are all different, the General Contractor must provide confirmation the materials and installation meet and/or exceed the project specifications. In addition, the General Contractor must confirm all materials needed for a complete building system are being provided as suppliers of the building components are stating that numerous materials, framing, installation, etc., is being provided by others. **Make Corrections Noted**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [jfmanager@lfmsdd.org](mailto:jfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.