

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

May 22, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

***Via Email to: wes@weavercm.com
No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	07501-007A
Date of Submittal:	May 16, 2013
Title:	Roof and Wall Panels for BH Solids (Biosolids Handling) Building
Specification Section:	07501
Manufacturers:	Heath Steel; SFS intec, Inc.

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. We acknowledge receipt of the Additional Submittal Review Comments provided by WCMI per correspondence dated May 16, 2013, and those provided by Heath Steel dated May 16, 2013.
2. In as much as we acknowledge receipt of the review comments, neither set of comments addresses Item 2.a. in GMS, Inc. shop submittal response letter dated April 19, 2013 which raises concern over the length of wall panels extending all the way to the eave. Due to the lack of response to this item, we will assume WCMI addresses this in their additional submittal review comments stating that the erector will field cut to the dimensions as shown on the Drawings and therefore, this is no longer a concern.
3. Per the Additional Submittal Review Comments provided by WCMI, we anticipate the installer's qualifications and their certifications will be provided in accordance with the requirements of the Project Specifications.

Mr. Wes Weaver
May 22, 2013
Page 2

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com

Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com

Ms. Solange Huggins, Project Engineer, Garney Construction, shuggins@garney.com

cc (w/attachment): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.