

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

March 6, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	08301-002
Date of Submittal:	February 3, 2012
Title:	Overhead Sectional Doors for Equipment & Maintenance Building
Specification Section:	08301 – Overhead Sectional Doors
Manufacturer:	Raynor

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We acknowledge the door nominal thickness is 1¾ inches in lieu of the specified 2-inch nominal thickness. Due to the specified minimum R value of 7.0 and the 1¾-inch nominal thickness door having an R value of 16.4, we will accept the 1¾-inch thick door.
2. The Contractor must coordinate the installation of door equipment with the metal building manufacturer to confirm the appropriate jamb and header materials are installed to accommodate a weathertight seal between the door and the building.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavercm.com](mailto:tammerman@weavercm.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.