

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

June 27, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com*  
*No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	08710-002A
Original Date of Submittal:	May 25, 2012
Title:	Hollow Metal Doors/Frames and Finish Hardware for Equipment and Maintenance Building
Specification Sections:	08100 – Metal Doors and Frames 08710 – Finish Hardware
Manufacturers:	Hager Co.; Stanley phi; Kaba Ilco; Reese Enterprises, Inc.; Cal-Royal Products, Inc.; Ives; Newco Door & Hardware, LLC; National Guard Products, Inc.; Pioneer Industries; Simplex

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. We acknowledge the comments provided by Newco that were included in the WCMI letter as part of this submittal. The first two initial comments were in regard to comments 2. 6) and 2. 7) from the initial shop submittal response letter dated May 3, 2012.

As noted in the original shop submittal response letter, we request the supplier/manufacturer coordinate with WCMI and the metal building manufacturer on the door frame and framing to be accomplished at the openings where 4" head and jambs are specified and the framed walls are 4", 6" and 8" walls. **Make Corrections Noted**

2. There was question whether the Schlage Rhodes lever handle could be used in lieu of the Schlage Sparta lever handle. We take no exception to the use of the Schlage Rhodes lever handle. **No Exception Taken**
3. In review of the hardware sets proposed for each door, please reference the Finish Hardware Schedule as detailed on Addendum No. Six (6). This shop submittal review will not include a detailed accounting of each part and piece to be utilized on each door. A prior submittal review of the doors included a review of the proposed parts and pieces to be incorporated into the project. This review includes verification that each door tag has been equipped with the

Mr. Wes Weaver  
June 27, 2012  
Page 2

hardware set that is detailed in Addendum No. Six (6). In addition, the handing of the door has been verified and the window lite to be installed in the door has been verified. Based on our cursory review, the doors, as proposed, with the accompanying hardware set are in accordance with the door schedule on the Construction Drawings. **No Exception Taken**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)

Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)

Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)

Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)

Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavercm.com](mailto:tammerman@weavercm.com)

Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.