

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

April 13, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavercm.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	09900-003
Date of Submittal:	April 12, 2012
Title:	Hi-Mil Sher-Tar Epoxy for Headworks Channels and Grit Chamber
Specification Section:	09900 – Painting
Manufacturer:	Sherwin Williams

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. As noted in prior electronic mail dated April 10, 2012, we take no exception to the Hi-Mil Sher-Tar epoxy with the following conditions based on the submittal information provided.
 - The cure requirements on the shop submittal indicate the temperature must be maintained at 50°F for a minimum of 10 hours after coating. This will be a requirement if this product is used. This is stated in the letter from the Sherwin Williams representative provided to us on April 10, 2012.
 - Measures must be implemented to mitigate the temperature drop should ambient air temperatures be forecasted to drop below the 50°F level.
 - If ambient air temperatures are forecasted to drop below the 50°F level and coating is scheduled, we request a procedural plan be implemented on how the coating will be applied and the temperature maintained for the minimum 10-hour period.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.