

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

June 17, 2013

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
c/o Garney Construction
7911 Shaffer Parkway
Littleton, CO 80127

*Via Email to: wes@weavercm.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	09900-009
Date of Submittal:	May 22, 2013
Title:	Alternate Paint Manufacturer for Exterior Doors & Frames
Specification Section:	09900
Manufacturer:	The Sherwin-Williams Company

The referenced submittal has been stamped "**No Exception Taken**". Our comments are as follows:

1. We take no exception to the Sherwin Williams DTM Acrylic Coating proposed for use.
2. We take no exception to the coating system data sheet which provides the surface preparation of SSPC-SP2, a primer coat with a dry film thickness (DFT) of 1-3, a second coat DFT of 2.5-4 and a third coat DFT of 2.5-4.0.
3. The shop submittal does not provide information on the factory primer/finish coat to be utilized. We request the Contractor make whatever corrections are necessary to ensure that the factory primer coating proposed for use with the DTM Acrylic Coating be utilized. We request a copy of the primer coating to be used be provided for record.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Adam Roeder, Weaver Construction Management, Inc., aroeder@weavercm.com
Ms. Solange Huggins, Project Engineer, Garney Construction, shuggins@garney.com

cc (w/attachments): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.